

Intertek

Intertek RTL Level 4



ASTA Recognized Laboratory

Recognition remains in force until further notice subject to the continuing compliance with the Regulations and Criteria of Competence for the ASTA Recognized Laboratory Scheme and is also subject to the conditions specified in the endorsement as varied from time to time.

Issued by:
Intertek Testing & Certification Ltd.
Registered office:
Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom
Registered No: 3272281 (England), VAT No: GB 672-7639-96.
asta@intertek.com
www.intertek.com

The following organization has been assessed and found to comply with the relevant requirements of ISO/IEC 17025 and the Intertek Recognized Laboratory Program Manual and accepted by Intertek as a Level 4 Recognized Testing Laboratory


kA Testing Facility

Leone Works, John Street, New Basford, Nottingham, NG7 7HK, United Kingdom

and is hereby authorised to undertake test work for ASTA certification purposes for the product types and standards identified on the endorsement forming part of this document.

Agreement Number:	2013-RTL-L4-49
Issue number:	6
Original issue date:	February 2005
Expiry date:	31 st January 2021

Name R W Hayward

Signature 

Date 16th February 2017

Intertek

Intertek RTL Level 4



ASTA Recognized Laboratory Endorsement page 1 of 1

Site(s) applicable to the recognition:

**kA Testing Facility
Leone Works
John Street
New Basford
Nottingham, NG7 7HL
United Kingdom**

Scope of recognition (generic products):

The performance of type tests to low and high voltage standards including temperature-rise up to 6000A, dielectric up to 130kV, impulse withstand up to 400kV, mechanical, creepage, clearance tests and IP tests.

Conditions applicable to the recognition:

The recognition applies to the testing of any manufacturer's apparatus within the conditions and requirements of Agreement No. 2013-RTL-L4-49.